TECUMSEH HERMETIC CONDENSING UNITS

Date: 9-7-95

MODEL AKA4460Y**XA (Formerly AK4460YA) R-134a 1/2 HP AIR COOLED



NOTE: DIMENSIONING = INCHES [MILLIMETERS]

Model	Dimensions				*Line Connection		Pumpdown 90 ° F 90% Full	Air CFM	Oil Chg oz.	Gr. Wt. Lbs.
	L	W	H	CH	Suct.	Liq.				
AKA4460Y**XA	17.4	14.0	10.9	10.1	1/2 F	1/4 F	—	350	17	68

*F=Flare, S=Solder, RF or RS= Rotolock Valve with Flare or Solder Connections
Factory charge: 20 psig nitrogen - MUST BE EVACUATED 60 HZ Performance

Approved Evap. Range		Ambient								
		90° F			100° F			110° F		
°F	PSIG	BTUH	Watts	Head	BTUH	Watts	Head	BTUH	Watts	Head
+20	18.4	3570	655	155	3180	655	170	2790	670	190
25	22.1	4000	700	160	3590	710	180	3180	715	200
30	26.0	4450	750	170	4000	760	190	3580	770	210
35	30.3	4900	800	180	4430	815	200	3990	830	220
40	35.0	5390	855	190	4880	875	210	4400	895	230
45	40.0	5880	915	200	5330	93 0	220	4850	96 0	240
50	45.3	6370	975	210	5800	1010	230	5290	1035	255
55	51.1	6880	1045	220	6290	1085	240	5750	1125	270

65 ° F return gas temp., 5 ° F subcooling

Date: 9-7-95

SPECIFICATIONS	AKA4460YXAXA	AKA4460YXDXA	AKA4460YXCXA
Nominal Voltage	115-60-1	230/208-60-1	240/220-50-1
Unit B/M	2C240-1	2D223-1	2D224-1
Voltage Range	126.5 to 103.5	253 to 187	264 to 198
Min. Circuit Ampacity	12.4	5.2	5.2
Max. Fuse Size (Amps)	20	15	15
Compressor Model	AKA4460YXA	AKA4460YXD	AKA4460YXC
Bill of Material	AK168AT-038-P2	AK168ET-038-P2	AK168JT-038-P2
RLA/LRA	9.5/48.0	4.8/23.0	3.9/21.0
Overload	8300MRAG17	8300MRPG19	8300MRAG28
Rel. Box Assy.	AE1227-008A	AE1227-010A	AE1227-012A
Relay	82498-1	82484-1	82494-1
Cap. Start	85PS165A53	85PS330C50	85PS330C50
Rating	161-193/165	72-88/330	72-88/330
Fan Motor	810M009B48	810M009B47	810M009B47
Alternate	810M009B24	810G009B25	810G009B25
Fan Blade		51551	
Condenser		50840-1	
Condenser Shroud		70766-1	
Unit Drawing		SU1909-26	
Schematic or Elect. Dwg.		90701-2	


START CAPACITOR
(NEUTRAL)
GREEN
GREEN
POWER CORD (GROUND TYPE)
IDENTIFICATION RIB (NEUTRAL)
IF USED
UNIT GROUND CONNECTION
FAN (CONDENSER)
RELAY
BLACK OR BLUE
YELLOW
OVERLOAD
RED
COMPRESSOR TERMINALS
NOTE !
1. CONNECT INCOMING GROUND LEAD TO GREEN SCREW.
2. WHEN T. P. CO. APPROVED ALTERNATE RELAY IS USED, CONNECT LEADS TO SAME NUMBERED TERMINALS REGARDLESS OF LOCATION.
3. MOUNT RELAY IN PROPER POSITION AS INDICATED ON RELAY BY "TOP" OR "↑ TOP".
WARNING: WIRING DIAGRAM MUST BE FOLLOWED AS SHOWN. ANY MISWIRING CAN CAUSE SERIOUS ELECTRICAL HAZARD AND POTENTIAL DAMAGE OR RUPTURE OF COMPONENT ELECTRICAL PARTS.
CHG. C
PART NO. 90701-2

U.L. Listed -----(60 HZ only)----File #SA2372 --------------Card Guide #SGYU
CSA Certified -------------Canadian File #12964C -----------USA File #8873C